# Optical cabinets 19 inch 600 or 800mm deep

**CABINET BZ19 800X600 36U**



**Aginode Ref:** 10243504

Optical cabinet with width 800, depth 600, heigth 1700 and a rack capacity 36U.

The 19" optical cabinets BZ19 can host all telecom equipment for 19'' size (optical modules, active equipments, patchpanel with RJ45 jacks, ⋯) and thus answer to any type of network installation.

The modular design is suitable for a wide range of requirements:

- Width 600 or 800mm
- Depth 600 or 800mm
- Usefull height 36Uor 42U

Cabinets are equipped with :

- Glass door opening to the left with key lock (right side mounting possible)
- Removable side panels with key lock (juxtaposition de 2 baies possibles)
- Removable rear panel
- Front racks 19'' with adjustable depth
- Rear racks 19'' for accessories
- Grounding bar
- Plate for incoming cables with brush mounted on the roof or base (if cabinet returned)

Optical equipment for Optical Fiber management :

- Fixing plate for clamp and fanout device (DEP, DSM, ⋯)
- Rear plate with 5 rings for cable management on the rear side
- Up and down cable trays for the jumpers management on the front side
- Rigth and left C profiles with 8 bobbin Ø50 kits (only with width 800)

## STANDARDS

Aginode specification

*All drawings, designs, specifications, plans and particulars of weights, size and dimensions contained in the technical or commercial documentation of Aginode is indicative only and shall not be binding on Aginode or be treated as constituting a representation on the part of Aginode.*

# Cabinet BZ19 800x600 36U

## Characteristics

| | |
|---|---|
| **구조적 특성** | |
| 색상 | 담회색 RAL 7035 |
| Material | 스틸 |
| **치수** | |
| Depth | 600 mm |
| Height | 1700 mm |
| Width | 800 mm |
| **사용 특성** | |
| Field of application | Indoor |
| Minimum static operating bending radius | 30 mm |
| Locking system | Key |
| Packaging | Pallet |
| Watertightness | IP 30 |

*All drawings, designs, specifications, plans and particulars of weights, size and dimensions contained in the technical or commercial documentation of Aginode is indicative only and shall not be binding on Aginode or be treated as constituting a representation on the part of Aginode.*